

RIC 2005 Session C3 -- Research Activities

Research Activities on Materials Aging Management


John W. Craig, Deputy Director
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission

March 9, 2005



Current NDE Is Better Than 10-20 Years Ago

- Probability of Detection (POD) has improved with time and improved techniques
- Smaller transducers help solve access problems
- Signal processing (and transducers) reduce noise effects
- Improved technologies
 - SAFT-UT
 - Phased Arrays





Performance Demonstration Is a Clear Benefit

- PDI Program to qualify inspectors and NDE procedures, in response to ASME Code Section XI, Appendix VIII
- Large number of inspectors tested have produced a large amount of aggregated data
- Capabilities and reliability have improved
 - Inspectors and techniques can be assessed quantitatively
 - Technology improvements can be implemented widely
 - Observed need for retraining and requalification
- The approach may be extended to other NDE methods, beyond UT
- Ongoing interactions between industry and NRC



NDE Capabilities

- The industry is refining and developing NDE techniques for characterizing known degradation mechanisms
 - Fatigue
 - IGSCC in BWR internals, steam generator tubes
 - Boric acid corrosion (BAC), wastage
 - PWSCC
 - Mockups being developed to approximate component geometries, relevant flaw characteristics
 - CRDM cracking, piping dissimilar metal welds
- Weaknesses remain



What Are the Weaknesses?

- Screening techniques for degradation we have not seen yet, damage precursors
- Maintaining inspector skills
 - Number of qualified inspectors declining
 - Costs, cost sensitivity are increasing
 - Relatively few flaws are found in the field
 - How to set re-training intervals?
- Improving efficiency of inspections
 - Pressure from decreasing outage times
 - Maintaining or improving effectiveness, reliability



Challenges for the Future

- Motivating research on NDE
 - Development of new technologies
 - Advances in existing techniques
 - Transducers
 - Signal processing
 - Shifting emphasis from reactionary to exploratory work
- Remaining material challenges
 - Coarse-grained materials (Inconel, cast SS, DMWs)
 - Weld geometry and access issues
 - Damage precursors, new degradation mechanisms